

Lake Temagami
2005 Sewage Inspection Summary
Ministry of the Environment, North Bay

Facility Type	Inspection Date	Pass/Fail	Identified Concerns
Private Cottage Corporation	July 18, 2005	Fail	Leaks identified in piping at main pump station. No direct discharge to the Lake.
Fishing Camp/Resort	July 19, 2005	Fail	Improperly designed sewage works. Sewage breakout onto the ground. No direct discharge to Lake
Children=s Camp	July 20, 2005	Fail	Sewage tile field failing due to poor design/construction and sewage breaking onto the ground. Suspect discharge to the Lake. Provincial Officer Order issued.
Children=s Canoe Tripping Camp	July 20, 2005	Fail	Some systems failing due to age. Sewage breakout onto to ground. No direct discharge to Lake.
Children=s Canoe Tripping Camp	July 20, 2005	Fail	Sewage (grey water pits) improperly designed and constructed. Sewage breaking onto the ground. No direct discharged to the Lake.
Children=s Canoe Tripping Camp	July 21, 2005	Pass	Sewage systems appear to be functioning because of limited usage due to camp=s program. (Canoe tripping camp)
Fishing Camp/Resort	July 21, 2005	Pass	System well maintained. No concerns identified.
Children=s Camp	July 22, 2005	Pass	Sewage system constructed as designed but over designed. Some recommendations to improve operations to reduce odours.
Fishing Camp/Resort	July 22, 2005	Pass	Sewage works operating as design. Recommendation to improve/upgrade a sewage works servicing a cabin.

Private Cottage (sewage works located on separate island)	August 17, 2005	Fail	Sewage works altered without approval and under designed. No direct discharge to Lake.
Private Cottage (Sewage works constructed off property on Crown land)	October 18, 2005	Pass	Sewage works has MOE approval. No concerns identified.
		6 fail 5 pass	

Note: Although the system has been identified as failed, steps have been and are being taken by the owners to rectify the concerns identified